

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department
Annual Periodical Renewal Fire Certificate

From:
 District Fire Officer
 Andhra Pradesh, Srikakulam

To:
 District Educational Officer,,
 Srikakulam

File No: 16505/SKLM/DFO/2021, Date:10/02/2021

Occupancy NoC RC Number: 474/A2/2015

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **Seethamahalakshmi DAV School, represented by Seethamahalakshmi DAV School, S.No.111, 113, 114, 115, 116, Annavaram Village and Panchayat, Palakonda Mandal, Srikakulam District - Regarding.**

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
 3. This Office NOC for Occupancy Rc No. 474/A2/2015, Dt.07/10/2015
 4. Renewal NOC For Occupancy 474/A2/2015, Dt.07/10/2018
 5. Online Application for Renewal NOC of Seethamahalakshmi DAV School, S.No.111, 113, 114, 115, 116, Annavaram Village and Panchayat, Palakonda Mandal, Srikakulam District - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 10-02-2021.

<< 0 >>

The Management of Seethamahalakshmi DAV School, represented by Seethamahalakshmi DAV School, S.No.111, 113, 114, 115, 116, Annavaram Village and Panchayat, Palakonda Mandal, Srikakulam District has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.87389/- vide challan No. 40107444712020, 31180346472019, Dated 06/11/2020 at SBI, SBI.

Seethamahalakshmi DAV School

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **Seethamahalakshmi DAV School S.No.111, 113, 114, 115, 116, Annavaram Village and Panchayat, Palakonda Mandal, Srikakulam District**, subject to the following conditions.

| Sl | As Builder | As Occupant | As Security Personnel |
|----|---|---|--|
| 1 | All the fire protection arrangements shall be maintained in good condition as seen during inspection. | All the escape/exit routes shall not be kept locked/blocked or encroached | All the occupants must know the correct method of operation of the fire fighting system installed. |

| | | | |
|---|--|--|--|
| 2 | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management. | All occupants shall be trained to operate the fire safety equipments during emergency. | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. |
| 3 | Addition / alteration, if any in the building may be verified by building authority. | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. | All security personnel shall be trained to operate the fire safety equipments during emergency. |
| 4 | This is Only for Fire Safety Point of View. | Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit. | Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows. |

4. This Annual Periodical Renewal Fire Certificate is valid from 07/10/2020 to 06/10/2025.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.



16505/SKLM/DF0/2021

Your Sincerely,

Chelva
District Fire Officer

Andhra Pradesh, Srikakulam

Copy to Management Seethamahalakshmi DAV School, Correspondent of Seethamahalakshmi DAV School, S.No.111, 113, 114, 115, 116, Annaram Village and Panchayat, Palakonda Mandal, Srikakulam District

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned